

The following questions were posed to the Court, along with a response:

One of the line items for this bid is; “Labor - Completion of Appendices C, D, F.0, F.1, and F.2”

Where do I find Appendices C, D, F.0, F.1, and F.2? **This is not applicable, you can leave this line item blank**

On the “Control” bid section is “Control panel to remain, reroute and reprogram audio” – I do not see the control panel on plan T700 – do you have additional info on this? **The existing control touch panel is located at the CRD station at the lower bench. Cabling is all routed to the AV rack within the courtroom. The court utilizes CFE PC’s to run XPANEL for control.**