

The following questions were posed to the Court, along with a response:

under the "Technical Statement of Work"

"4. An interpreter system within the courtroom will be provided and will utilize a telephone interpreting program (TIPS) and an interpreter box with a headset/microphone at the defense table."

I do not see an interpreter system on the equipment list, nor do I find any specifications for it. Can you provide more info? The interpreter system will utilize the wireless microphone and return headphone channels with routing through the DSP. The witness faceplate will have cabling to support a Quantum interpreter box with microphone & headset that will also be programmed according through the DSP. An Quantum / 001952 V2 can be included in miscellaneous equipment in Schedule B

Plan T600 shows an equipment rack (on the equipment list) and 12 faceplates (NOT on the equip list). Are we to provide these faceplates? If so, do we include the cost for the faceplates under miscellaneous equipment? Yes, they are to provide new plates and connectors and can include those in the miscellaneous equipment in Schedule B